


Dimensions for Accessibility from the Inclusivity Assessment Tool



Route of Travel	
Width of route of travel at its narrowest point	36"
Slope of route of travel at its steepest point	8%
Wheelchair Maneuvering Space	60" circle
Parking	
Clearly marked with upright signs; international symbol of accessibility displayed	
Width of accessible parking spots	96"
Width of access aisle (96" in NY)	60"
Ramps	
Width of ramp at its narrowest point	36"
Slope of ramp	8% or less
Depth of ramp landing	60" or more
Doors	
Distance between doors in a series	48" or more
Clear open width of door	32" or more
Opening force of interior doors	5 pounds or less
Clear space on pull side of door	18" or more
Registration/Check-In Area	
Registration counter height	36" or less
Restroom	
Width of the toilet stall	60"
Depth of the toilet stall – varies; see this link for details: http://www.access-board.gov/guidelines-and-standards/buildings-and-sites/about-the-ada-standards/ada-standards/chapter-6-plumbing-elements-and-facilities	varies
Distance of center line of toilet from nearest side wall	16-18"
Toilet seat height	17-19"
Sink height	34" or less
Depth of knee space under sink (from outer edge of sink to pipes or other obstructions under sink)	at least 8"
Soap dispenser and hand dryer/paper towels height	48" or less
Elevator	
Elevator control panel height	48" or less
Elevator door width	36" or more



www.inclusiverec.org
inclusiverec@cortland.edu